



## Type 8

### Resilient Pipe Guides

---

Pipe Guides shall consist of a telescopic arrangement of two sizes of steel tubing or piping separated by a minimum ½" thickness of 60 Durometer elastomer.

The height of the guides shall be preset with a shear pin to allow vertical motion due to pipe expansion or contraction. Shear pin shall be removable and replaceable to allow for selection of pipe movement.

Guides shall be capable of +/- 1 5/8" motion, or to meet location requirements.

**The VMC Group**

Headquarters: 113 Main Street • Bloomingdale, NJ 07403 | Houston: 11930 Brittmoore Park Drive • Houston, TX 77041

Phone: 973.838.1780 | Toll Free: 800.569.8423

[www.thevmcgroup.com](http://www.thevmcgroup.com)