



Type C

Concrete Inertia Bases

Bases shall be of welded steel construction and rectangular in shape. Industry standard rebar shall be pre-welded to the base. Non-standard rebar is unacceptable. All perimeter members shall be structural channels with a minimum depth equal to 1/12 of the longest dimension between isolators. Height saving brackets shall be employed at all isolator locations to provide a minimum base clearance of 2". Minimum depth of inertia base shall be 6".

Anchor bolt templates shall be pre-installed to accept mounting hole locations of the isolated equipment.

Isolators shall be of Type 3 or 3R.

The VMC Group

Headquarters: 113 Main Street • Bloomingdale, NJ 07403 | Houston: 11930 Brittmoore Park Drive • Houston, TX 77041

Phone: 973.838.1780 | Toll Free: 800.569.8423

www.thevmcgroup.com