



## Type G

### Floor Stands

---

Floor Stands shall be constructed of structural steel tubing top and bottom with provisions for turning vanes where required. Lower framing shall be provided with the capability of vertical adjustment of  $\pm 3/4$ " to account for variation in slab elevation. Intermediate vertical members shall be provided to allow for a rigid upper frame to support the equipment.

**The VMC Group**

Headquarters: 113 Main Street • Bloomingdale, NJ 07403 | Houston: 11930 Brittmoore Park Drive • Houston, TX 77041

Phone: 973.838.1780 | Toll Free: 800.569.8423

[www.thevmcgroup.com](http://www.thevmcgroup.com)