



Type G-S

Seismic Floor Stands

Seismic Floor Stands shall be constructed of structural steel tubing with provisions for positively attaching the equipment to the top frame, and turning vanes where required. Intermediate vertical members shall be provided to allow for a rigid upper frame to support the equipment. Isolators shall be provided with the capability of vertical adjustment of $\pm 3/4$ " to account for variation in slab elevation.

Isolators shall be of Type 2S or 3S.

The VMC Group

Headquarters: 113 Main Street • Bloomingdale, NJ 07403 | Houston: 11930 Brittmoore Park Drive • Houston, TX 77041

Phone: 973.838.1780 | Toll Free: 800.569.8423

www.thevmcgroup.com